

1. Approving Competent Authority / Country
CAA.UK

2. **AUTHORISED RELEASE CERTIFICATE**
EASA FORM 1

3. Form Tracking Number:
W201917880

4. Organization Name and Address:
Avia Technique Ltd.
Unit 1,3,4 & 6 Fishponds Estate
Fishponds Road
Wokingham, Berkshire, United Kingdom RG41 2QJ
Ph: +441189789789, Fax: +441189784511

5. Work Order / Contract / Invoice Number:
W2019177880
112020

6. Item:	7. Description:	8. Part Number:	9. Quantity:	10. Serial Number:	11. Status / Mark:
1	Fire Extinguisher	33007507	1.00	4545951	Overhauled

12. Remarks:
CMM: 28-20-11 Revision: 8

Next Overhaul/Hydrostatic Test Due: 10/2024.
Last Overhaul/Hydrostatic Test: 10/2019.
Checked Weight: 3.93 Lbs.
Cartridge P/N: 30903828. S/N: 0093WF. Life Expires: 03/2029. Filled.

Avia Technique have checked and verified that there are no pertinent AD's or SB's relevant.

13a. Certifies that the items identified above were manufactured in conformity to:

Approved design data and are in a condition for safe operation.
 Non-approved design data specified in Block 12

Part-145, A.50 Release to Service Other regulation specified in Block 12

Certifies that unless otherwise specified in Block 12, the work identified in Block 11 and described in Block 12 was accomplished in accordance with Part-145, and in respect to that work the items are considered ready for release to service.

13b. Authorised Signature:	13c. Certificate / Approval Ref No.:	14b. Authorised Signature:	14c. Certificate / Approval Ref No.:
			UK. 145.00846
13d. Name	13e. Date (dd/mm/yyyy):	14d. Name	14e. Date (dd/mm/yyyy):
		Jack West	22/Oct/2019

USER / INSTALLER RESPONSIBILITIES

This certificate does not automatically constitute authority to install the item(s).

Where the user/installer performs work in accordance with regulations of an Airworthiness Authority different than the Airworthiness Authority specified in block 1, it is essential that the user/installer verifies that his/her Airworthiness Authority accepts items from the Airworthiness Authority specified in block 1.

Site permits, block 13a and 14a do not constitute installation certification. In all cases aircraft maintenance records must contain an installation certification issued in accordance with the national regulations by the user/installer before the aircraft may be flown.



Avia Technique Ltd.
Unit 1,3,4 & 6 Fishponds Estate
Fishponds Road
Wokingham, Berkshire, United Kingdom
RG41 2QJ
Ph: +441189789789, Fax: +441189794511

Tear Down/Inspection

Work Order #: W201917880
Date Printed: 11/10/2019
Page: 1

To:
Burwood Aviation Supplies Ltd
8 Bessemer Close
Burwood House
Verwood, Dorset BH31 6AZ
United Kingdom

Ship To:
Burwood Aviation Supplies Ltd
8 Bessemer Close
Burwood House
Verwood, Dorset BH31 6AZ
United Kingdom

Reference: 11/2020
Date Received: 10/10/2019
Part Number: 33007507
Description: Fire Extinguisher
Serial Number: 45459B1

Customer Remarks:

Overhaul

Results from inspection:

Fire Ex Overhaul

Overhaul is Required.

ID Plate is Full Therefore Replacement ID Plate Required.

Cartridge is PMA.

Cartridge P/N: M30903828. S/N: 01903. Life Expires: 05/2024.

Pressure switch functional tests

The Pressure Switch passed functional testing when full but may fail when removed/fully tested. In this case, the customer will be re-quoted for the full cost of a new Pressure Switch

Date of manufacture

11/2000

Corrective actions:

Overhaul with reference to the correct CMM Rev

Replace Cartridge.

Replace ID Plate.

Inspection report generated by: Aaron Connelly